



## THE CITY OF SAN DIEGO

### FHPS POLICY I-00-6

### ILLUMINATED DIRECTORY

#### ***I. PURPOSE***

This policy is intended to provide requirements to clearly identify and mark proper addresses pursuant to UFC 901.4.4.

#### ***II. SCOPE***


This policy applies to newly constructed condominium complexes, apartment complexes, mobile home parks and multiple commercial building sites and, on a case by case basis, existing sites.

#### ***III. PERMITS***

An electrical permit to supply power to the sign must be obtained from the City of San Diego.

#### ***IV. REQUIREMENTS***

A. The directory sign shall consist of a map to include the following:

1. Name of complex.
2. All access roads and any gates.
3. Fire hydrant locations. (  = symbol)
4. A plot plan showing private roads.
5. Building locations with addresses and unit numbers.
6. A reference point on the plot plan indicating the location of the directory. (You are here.)



#### **Fire and Hazard Prevention**


Fire and Life Safety Services • 1010 Second Avenue, Suite 300 • San Diego, CA 92101  
Tel (619) 533-4400 Fax (619) 544-6806

7. A north direction indicator, correctly oriented to the viewing position.  
(↑N = Symbol)
- B. The developer or the property owner shall submit to Planning and Development Review, Fire Plan Check Section, for review and approval, a detailed plan showing size, materials, method of construction, and location of installation. Additionally, electrical components and wiring will require approval from Electrical Plan Review.

Directories shall be located on the right side of the access roadway.

- C. Figure 1 indicates the minimum dimensions of the directory.

**FIGURE 1**



**FHPS Policy I-00-6**

Page 3

- D. Sign(s) shall be maintained in accordance with this policy.
- E. Existing buildings must comply with this policy when deemed necessary by Fire and Life Safety Services.

Promulgated by:                     [signed]                     Date: 3/2/2000

Rev. 3/2/2000